



SUPPLIER DECLARATION OF CONFORMITY (SDOC)

IN ACCORDANCE WITH ISO/IEC 17050-1:2004

SDoC Identification Number - TNL0020.2012			
ISSUER DETAILS			
NAME (of New Zealand manufacturer or importer)		CONTACT ADDRESS	
TRANSNET NZ LTD		20 NEIL PARK DRIVE EAST TAMAKI AUCKLAND	
NEW ZEALAND COMPANY NUMBER (IF APPLICABLE)			
1033992			
TELEPHONE	FAX	EMAIL ADDRESS	
09 274 3340	09 274 5490	sales@transnet.co.nz	
MEDIUM RISK ARTICLE - DETAILS (BRAND, PRODUCT TYPE, MODEL, RATINGS, AS APPLICABLE)			
LEDFL12-50AC			
85-265V AC 50W 50Hz IP65			
THE MEDIUM RISK ARTICLE, LISTED ABOVE, FULLY COMPLIES WITH THE CITED STANDARD(S), AS LISTED:-			
Standard number & issue year:- AN/NZS 60598.2.5:2002		Standard number & issue year:- AS/NZS 60598.1.2003	
Standard Title:- LUMINAIRES - PARTICULAR REQUIREMENTS - FLOODLIGHTS		Standard Title:- LUMINAIRES - General requirements and testing	
Edition / Amendment status:-	2002	Edition / Amendment status:-	2003
OR COMPLIES WITH THE CONFORMITY COOPERATION AGREEMENT - NO			
NAMES AND ADDRESSES OF ANY TESTING ORGANISATION OR BODY			
NAME(S)		ADDRESS(ES)	
Spectrum Laboratories		1/25 Highbrook Drive, East Tamaki, Auckland	
Bontek Compliance Testing Laboratory Ltd		1/F, Block East H-3, Oct Eastern Ind. Zone, Qiacheng East Road, Nanghan, Shenzhen, China.	
Reference to relevant test reports/certification, and issue date of the reports/certification, that show how compliance is achieved:-			
STANDARD(S) OR DOCUMENT(S) USED, TO SHOW HOW COMPLIANCE WITH CITED STANDARD IS ACHIEVED:-		REPORT/CERTIFICATION OR DOCUMENT REFERENCE N°(S):-	ISSUE DATE(S)
AS/NZS 60598.2.1:1998		5591:Spectrum Laboratories	07/09/2012
EN60598-1:2008+A11:2009; EN60598-2-5:1998		BCT 12GR-0999S	13/07/2012
EN55015:2006+A1:2007; EN61547:1995+A1:2000 EN61000-3-2:2006; EN61000-3-3:1995+A1:2001+A2:2005		BCT 12GR-0999E	12/07/2012
Reference to any management systems involved:-			
Additional Information:- Refer to supporting documentation:			
DECLARATION			
I hereby declare that the above specified fittings or electrical appliances comply with the requirements of Regulation 83 of the Electricity (Safety) Regulations 2010.		SIGNED FOR AND ON BEHALF OF:	
		TransNet NZ Ltd	
		NAME & POSITION, AS AUTHORIZED BY THE ISSUER	
		Phillip Hogg - Applications Engineer	
SIGNATURE		DATE	
			
Issuer Identification (as affixed to the article)		12/09/2012	